



# STANDARD APPLICATION

FOOT MOUNTED MOTOR  
WOUND ROTOR

TYPE - A000  
STYLE - WCO/WCS

UNIT SHOWN IN ASSEMBLY  
POSITION A101 - F1

RUNOUT TOLERANCE

SHAFT	.002
-------	------

FEET TO SHAFT CENTERLINE  
TOLERANCE + .000 - .031

Frame	B	C	D	E	F	L	M	N	U	V	W
254 U	10.50	27.31	6.25	5.00	4.12	11.12	11.88	4.31	1.3750	3.50	.56
256 U	12.25	29.06			5.00	12.00	12.75		1.3745		

Frame	KEY	AE	BA	FN	FU	FV	FW	FKEY			
254 U	.31	6.25	8.31	4.75	1.3750	3.50	1.00	.31			
256 U					1.3745						

REULAND ELECTRIC CO.



Industry, Calif. Howell, Mich.

replaces  
NONE

DRAWN *JV*  
APPR. *JV*

◆ Revised  
● Added  
NEW  
6/8/84

dwg no  
RDA21-0120